



2nd International Conference on Intelligent Computing, Communication & Convergence  
(ICCC-2016)

Srikanta Patnaik, Editor in Chief

Conference Organized by Interscience Institute of Management and Technology

Bhubaneswar, Odisha, India

## Application of Wavelet Technique for Fault Classification in Transmission Systems

Avagaddi Prasad\*, J. Belwin Edward

*School of Electrical Engineering, VIT University, Vellore, Tamil Nadu, 632014, India.*

---

### Abstract

Transmission systems (TS) plays a major role in electrical power systems. The interruption caused to the consumer because of TS faults is substantial. So TS needs a proper protection scheme to ensure continuous power supply to the consumers. This study proposes a novel scheme using wavelet technique for classification of faults in TS. In order to do so, the proposed scheme uses current measurements of just one side of the transmission line. Simulations are performed under different fault conditions using MATLAB. The stability of the proposed scheme under various cases is tested and reliable results have been obtained.

© 2016 The Authors. Published by Elsevier B.V. This is an open access article under the CC BY-NC-ND license (<http://creativecommons.org/licenses/by-nc-nd/4.0/>).

Peer-review under responsibility of the Organizing Committee of ICCC 2016

*Keywords:* Fault; Fault classification; Transmission systems; Transmission line protection; Wavelet technique; Multi resolution analysis

---

---

\* Corresponding author. Tel.: +91 7845609183.

E-mail address: [prasadavagaddi@gmail.com](mailto:prasadavagaddi@gmail.com)

## 1. Introduction

Here in this world, major number of problems are linked with population. The population on the earth increasing day by day. Due to this the requirement of energy in daily life gradually increasing. Electricity is the one of the basic need for survival to everyone on this earth. And hence the demand for electricity is raising, which means there is a necessity for more power generation. It is a challenging task for power engineers to provide good quality and uninterrupted power to the consumers. Generally the power system is divided into four parts namely, generation, transmission, distribution and utilization. Out of all these transmission plays major role and it is like a heart of the entire power system. But in entire power system maximum number of faults occurs in transmission systems. Transmission can be done in two ways, one is over head and other is underground. The predominant way to transmit the power is by using over headlines due to its inherent advantages over underground cables. Overhead transmission lines (OHTL) are exposed to atmospheric conditions because of this the possibilities of fault occurrence in OHTL is more [1]. Henceforth the main objective of power engineers is to implement a better protection scheme to TS.

Faults in OHTL are mainly classified into two types, one is open conductor (series) and short circuit (shunt) faults. Series faults are again classified into two types, one is one open conductor faults and other is two open conductor fault. Compared to shunt faults, open conductor faults very rarely occur. The most commonly occurring faults in transmission lines are short circuit faults. Short circuit faults are classified into two types, symmetrical faults and unsymmetrical faults. Symmetrical faults are 3-phase faults, these are most sever faults. Unsymmetrical faults are line to ground, line to line and double line to ground faults. The most frequently occurring fault in TS is line to ground fault. Fault analysis can be divided into three parts namely, fault detection, fault classification and fault location. Fault classification is one of the major task in fault analysis [2]. There are a couple of techniques that can be employed in simulation for this purpose. The major techniques are wavelet technique [3], [9], [12], artificial neural networks [5], [11], [14], fuzzy logic [4], [13], [15], wavelet-neural networks [8], wavelet-fuzzy [10], neuro-fuzzy [6], [7]. The accuracy and time response of wavelet approach is better than all the other major techniques and it provides much better results. In order to identify the nature of faults, wavelet techniques are extensively used to solve complex protection issues. This article presents a novel approach using application of wavelet technique for fault classification using one of the terminal end currents of the TS.

This paper is prepared as follows. Section 2 gives introduction to wavelets. Section 3, explains the classification of faults using wavelet technique. Section 4, explains the outcomes of the presented technique. Lastly, Section 5 gives the conclusion.

## 2. Wavelet Technique

Wavelet technique is a powerful mathematical tool, useful for processing signals. Wavelet technique appropriately chooses a proper wavelet function known as mother wavelet and this selected function is analysed using translated and scaled versions. It can analyse the transient, non-stationary or time varying phenomena. Multi resolution analysis (MRA) is one of the best tools to analyse the signals at different frequencies with different resolutions. MRA is designed to give poor time resolution and good frequency resolution at low frequencies, poor frequency resolution and good time resolution at high frequencies. This approach mainly useful for low frequency component signals for long durations and high frequency component signals for short durations. Another best application of wavelet technique is multi-level decomposition. Signal can be decomposed until individual details contains a single sample by using multi-level decomposition.

Wavelet technique has been in operation in lot of different areas and provides an added advantage of low time response, which improves system efficiency. It has the ability of performing local analysis to the best level without hampering lot of time frequency data. Hence wavelet technique will be very useful in the power system fault analysis and so this article presents a novel approach using wavelet technique to identify nature of faults.

## 3. Fault classification using wavelet technique

The power system model considered for the simulation is as shown in single line diagram in Fig. 1. A three phase transmission line of 200-km, operating with 400-kV sources at a load angle of  $20^\circ$  has been for simulation of proposed technique. The three phase currents are indicated as A, B and C respectively. And the ground is represented as G.




Fig. 1. Power system model

The below figures (Fig. 2. (a)-(i)) shows the simulation outputs of phase currents for different faults under various operating conditions.




Fig. 2. (a) Phase currents for Healthy system. (b)-(e) Phase currents at 50km,  $R_f=100 \Omega$  for AG, BC, CAG and ABC faults respectively. (f)-(i) Phase currents at 150km,  $R_f=100 \Omega$  for AG, BC, CAG and ABC faults respectively.

In this work, the application of wavelet technique is applied to fault detection and classification is done using one terminal end currents only. This approach uses discrete wavelet transform (DWT) with MRA. All three phase currents are decomposed to approximations (A) and details (D) by using db1 wavelet. The abnormal condition in each phase current can be found out by using details (D1) of the first decomposition level. The norm of detail coefficients can be calculated by using the following equation,

$$\|D1\| = \left[ \sum_{k=1}^{n_d} |D1(k)| \right]^{1/2} \tag{1}$$

Where  $n_d$  indicates number of the detail coefficients at a certain level.

If the calculated norm value is more than threshold value, then that phase is called faulty phase. If all three phasecurrent norm values are less than thresholds, transmission system is in healthy condition.

#### 4. Results

The below figures (Fig. 3 - Fig.14) shows the norm of D1 coefficients for different type of faults. The threshold value for the selected system is 0.25.




Fig. 3. Norm of D1 coefficients for Healthy System




Fig. 4. Norm of D1 coefficients for AG fault




Fig. 5. Norm of D1 coefficients for BG fault




Fig. 6. Norm of D1 coefficients for CG fault




Fig. 7. Norm of D1 coefficients for AB fault




Fig. 8. Norm of D1 coefficients for BC fault




Fig. 9. Norm of D1 coefficients for CA fault




Fig. 10. Norm of D1 coefficients for ABG fault




Fig. 11. Norm of D1 coefficients for BCG fault




Fig. 12. Norm of D1 coefficients for CAG fault




Fig. 13. Norm of D1 coefficients for ABC fault




Fig. 14. Norm of D1 coefficients for ABCG fault

Table 1. A summary of fault classification at a loadangleof $20^0$  and  $R_f=100 \Omega$

| S. No. | Applied Fault Type | Description   | Discovered Fault Type | Figure No. |
|--------|--------------------|---|-----------------------|------------|
| 1      | Healthy            | Norm values of all three phase currents less than threshold value   | Healthy               | 3          |
| 2      | AG                 | Norm value of Phase A current exceeds threshold value               | AG                    | 4          |
| 3      | BG                 | Norm value of Phase B current exceeds threshold value               | BG                    | 5          |
| 4      | CG                 | Norm value of Phase C current exceeds threshold value               | CG                    | 6          |
| 5      | AB                 | Norm values of Phase A and Phase B currents exceeds threshold value | AB                    | 7          |
| 6      | BC                 | Norm values of Phase B and Phase C currents exceeds threshold       | BC                    | 8          |

| S. No. | Applied Fault Type | Description   | Discovered Fault Type | Figure No. |
|--------|--------------------|---|-----------------------|------------|
| 7      | CA                 | Norm values of Phase C and Phase A currents exceeds threshold value | CA                    | 9          |
| 8      | ABG                | Norm values of Phase A and Phase B currents exceeds threshold value | ABG                   | 10         |
| 9      | BCG                | Norm values of Phase B and Phase C currents exceeds threshold value | BCG                   | 11         |
| 10     | CAG                | Norm values of Phase C and Phase A currents exceeds threshold value | CAG                   | 12         |
| 11     | ABC                | Norm values of all three phase currents exceeds threshold value     | ABC                   | 13         |
| 12     | ABCG               | Norm values of all three phase currents exceedsthreshold value      | ABCG                  | 14         |

## 5. Conclusion

The application of wavelet technique for classification of faults in overhead transmission lines has been presented in this article. The DWT collaborated with MRA was used to overcome the disadvantages of earlier techniques. DWT is used to decompose current signals into different frequency bands using MRA and based on it the nature of fault is identified. The nature of faults is classified accurately by using details (D1) at the first decomposition level of currents. If the calculated norm value of details in any phase exceeds the threshold value, it indicates that particular phase is under fault condition, if not it indicates that phase is in healthy condition. The simulations have been carried out under different varying conditions using MATLAB/Simulink. The presented approach gives correct results for any type of fault and this approach can be used apply for high fault resistances up to 500  $\Omega$ .

## References

- [1] Ross TW, Bell HG. Recent developments in the protection of three-phase transmission lines and feeders. *Electrical Engineers, Journal of the Institution of*. 1930; 68(403):801-23.
- [2] Girgis A, Johns MB. A hybrid expert system for faulted section identification, fault type classification and selection of fault location algorithms. *Power Delivery, IEEE Transactions on*. 1989; 4(2):978-85.
- [3] Youssef OA. Fault classification based on wavelet transforms. In *Transmission and Distribution Conference and Exposition*, 2001 IEEE/PES 2001; 1: pp. 531-536.
- [4] Youssef OA. A novel fuzzy-logic-based phase selection technique for power system relaying. *Electric Power Systems Research*. 2004; 68(3):175-84.
- [5] Mahanty RN, Gupta PD. Application of RBF neural network to fault classification and location in transmission lines. *IEEE Proceedings-Generation, Transmission and Distribution*. 2004; 151(2):201-12.
- [6] Wang H, Keerthipala WW. Fuzzy-neuro approach to fault classification for transmission line protection. *Power Delivery, IEEE Transactions on*. 1998; 13(4):1093-104.
- [7] Vasilic S, Kezunovic M. Fuzzy ART neural network algorithm for classifying the power system faults. *Power Delivery, IEEE Transactions on*. 2005; 20(2):1306-14.
- [8] Silva KM, Souza BA, Brito NS. Fault detection and classification in transmission lines based on wavelet transform and ANN. *Power Delivery, IEEE Transactions on*. 2006; 21(4):2058-63.
- [9] Megahed A, Bayoumy AE. Usage of wavelet transform in the protection of series-compensated transmission lines. *Power Delivery, IEEE Transactions on*. 2006; 21(3):1213-21.
- [10] Youssef OA. Combined fuzzy-logic wavelet-based fault classification technique for power system relaying. *Power Delivery, IEEE Transactions on*. 2004; 19(2):582-9.
- [11] Seydtabaai S. Improvement in the performance of neural network-based power transmission line fault classifiers. *IET generation, transmission & distribution*. 2012; 6(8):731-7.
- [12] Pérez FE, Orduna E, Guidi G. Adaptive wavelets applied to fault classification on transmission lines. *Generation, Transmission & Distribution, IET*. 2011; 5(7):694-702.
- [13] Samantaray SR. A systematic fuzzy rule based approach for fault classification in transmission lines. *Applied Soft Computing*. 2013; 13(2):928-38.
- [14] He Z, Lin S, Deng Y, Li X, Qian Q. A rough membership neural network approach for fault classification in transmission lines. *International Journal of Electrical Power & Energy Systems*. 2014; 61:429-39.
- [15] Prasad A, Edward JB, Roy CS, Divyansh G, Kumar A. Classification of Faults in Power Transmission Lines using Fuzzy-Logic Technique. *Indian Journal of Science and Technology*. 2015; 8(30):1-6.